

**Published: Not required to be published until after a discharge event has occurred. During discharge sampling at point 19 to be taken daily from sedimentation Dam Overflow. During discharge sampling at point 17 and 18 to be taken twenty four hours after discharge from point 19.**  
**Licensee: Cargill Narrabri**  
**EPL No: 902**

**Qualifications related to surface water**

Samples taken as per approved methods

Location/EPA I.D. no	Date	Volume	Measurement Period and Monitoring Frequency Required by Licence	Units of Measure	Year to Date			
					Min Value	Max Value	100 Percentile Limit	Exceeds (yes/no)
			During any discharge from Point 19					
19	04/04/2015	BOD	5	mg/L			20	No
		Oil and Grease	7	mg/L			10	No
	16:30	pH	6.9	pH			6.5-8.5	No
		Total Suspended Solids	49	mg/L			50	No
17	04/04/2015	Oil and Grease	<5	mg/L			-	
		pH	6.6	pH			-	
	16:45	Total Suspended Solids	640	mg/L			-	
18	04/04/2015	Oil and Grease	<5	mg/L			-	
		pH	6.5	pH			-	
	17:00	Total Suspended Solids	800	mg/L			-	