

Published: Not required to be published until after a discharge event has occurred. During discharge sampling at point 19 to be taken daily from sedimentation Dam Overflow. During discharge sampling at point 17 and 18 to be taken twenty four hours after discharge from point 19.
Licensee: Cargill Narrabri
EPL No: 902

Qualifications related to surface water

Samples taken as per approved methods

Location/EPA I.D. no	Date	Volume	Measurement Period and Monitoring Frequency Required by Licence	Units of Measure	Year to Date			
					Min Value	Max Value	100 Percentile Limit	Exceeds (yes/no)
			During any discharge from Point 19					
19	24/03/2014	BOD	72	mg/L			20	Yes
		Oil and Grease	<5	mg/L			10	No
	10:45	pH	7.4	pH			6.5-8.5	No
		Total Suspended Solids	26	mg/L			50	No
17	24/03/2014	Oil and Grease	<5	mg/L			-	
		pH	6.8	pH			-	
	10:15	Total Suspended Solids	350	mg/L			-	
18	24/03/2014	Oil and Grease	<5	mg/L			-	
		pH	7.3	pH			-	
	10:30	Total Suspended Solids	160	mg/L			-	